

ENTEBBE AREA**Report date:** 30th December -2015**Table:** Water quality for Selected points in Entebbe during the week of 24th December 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Imperial Resort	Anderita	Kabale	Bendeg ere	Kasen yi	
CODE		N047	N048	N049	N050	N051	N052	N053	
pH	7.6	7.4	7.2	6.8	6.7	6.9	7.0	5.5 – 8.5
Turbidity	NTU	2.27	0.14	0.40	1.00	0.10	0.20	0.30	≤5.00
Colour	PtCo.	30	0	7	6	11	8	2	≤15
Iron	Mg/l	0.03	0.00	0.00	0.00	0.00	0.00	0.00	≤0.30
Residue Aluminium	Mg/l	N/A	N/A	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	N/A	0.76	0.30	0.40	0.20	0.30	0.20	0.20 – 0.50
Faecal- Coliform	CFU/ 100 mL	41	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required