

ENTEBBE AREA**Report date:** 30th November -2015**Table:** Water quality for Selected points in Entebbe during the week starting 26th November 2015

Parameter				Monitoring points				National Standard For potable water quality
	Unit	Raw water	Final water	Water in Supply				
				Busamba ga	Garuga Stand Pipe	Namulanda	Kawuku	
CODE		N001	N004	N021	N025	N029	N030	
pH	NA	7.4	7.2	7.2	7.4	7.5	7.5	5.5 – 8.5
Turbidity	NTU	3.11	0.24	0.20	0.60	0.50	0.20	≤5.00
Colour	PtCo.	24.10	0.14	0	3	2	0	≤15
Iron	Mg/l	0.05	0.00	N/A	N/A	N/A	N/A	≤0.30
Residue Aluminium	Mg/l	N/A	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	N/A	0.84	0.30	0.20	0.40	0.40	0.20 – 0.50
Faecal- Coliform	CFU/ 100 mL	1	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required