

**ENTEBBE AREA****Report date:** 28<sup>th</sup> September -2015**Table:** Water quality for Selected points in Entebbe during the week of 25<sup>th</sup> September 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Imperi al Resort Hotel	Bweba jja	Bendege re	Kasenyi	Wamala	
Codes		N4330	N4331	N4332	N4333	N4334	N4335	N4336	
pH	....	7.9	7.2	7.6	7.6	7.2	7.8	7.4	5.5 – 8.5
Turbidity	NTU	2.29	1.41	0.40	0.10	0.20	0.10	0.30	≤5.00
Colour	PtCo.	28	0	1	1	2	0	2	≤15
Iron	Mg/l	0.04	0.00	N/R	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/l	N/R	0.00	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/R	0.79	0.30	0.30	0.30	0.20	0.02	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	14	0	0	0	0	0	0	0

N/R-Not Required