

ENTEBBE AREA**Report date:** 7th October -2015**Table:** Water quality for Selected points in Entebbe during the week of 2nd October 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply				
				Kabala	Garuga	Geological	Kawuku	
CODE		N001	N004	N022	N025	N018	N030	
pH	7.4	7.26	7.6	7.7	7.5	7.7	5.5 – 8.5
Turbidity	NTU	2.60	0.19	0.40	0.20	0.20	0.20	≤5.00
Colour	PtCo.	37	1	3	0	0	1	≤15
Iron	Mg/l	0.100	0.000	NR	NR	NR	NR	≤0.300
Residue Aluminium	Mg/l	N/R	0.00	NR	NR	NR	NR	≤0.20
Free chlorine	mg/L	N/R	0.83	0.30	0.20	0.20	0.30	0.20 – 0.50
Faecal- Coliform	CFU/ 100 mL	19	0	0	0	0	0	0