

## ENTEBBE AREA

**Report date:** 13<sup>th</sup> June 2015

**Table:** Water quality for selected points in Entebbe during the week of 6<sup>th</sup> July 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply				
				Nakiwogo	Busambaga	Garuga	Kawuku	
pH	...	6.44	6.86	7.17	7.12	7.06	7.43	5.5 – 8.5
Turbidity	NTU	4.27	0.25	0.2	0.3	0.4	0.2	≤5
Colour	PtCo.	42	0	1	0	3	0	≤15
Free chlorine	mg/L	NA	0.97	0.5	0.4	0.4	0.3	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	16	0	0	0	0	0	0