

ENTEBBE AREA**Report date:** 22nd September -2015**Table:** Water quality for Selected points in Entebbe during the week of 18th September 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Anderit a Hotel	Kabale	Bendeger e	Kasenyi	Kakindu	
CODE		N4323	N4324	N4325	N4326	N4327	N4328	N4329	
pH	7.5	7.2	6.7	6.8	7.0	7.1	7.1	5.5 – 8.5
Turbidity	NTU	1.89	1.16	0.4	0.3	0.20	0.20	0.60	≤5.00
Colour	PtCo.	28	15	1	0	1	1	0	≤15
Iron	Mg/l	0.080	0.000	NR	NR	NR	NR	NR	≤0.300
Residue Aluminium	Mg/l	N/R	0.00	NR	NR	NR	NR	NR	≤0.20
Free chlorine	mg/L	N/R	0.94	0.20	0.50	0.30	0.20	0.02	0.20 – 0.50
Faecal-Coliform	CFU/ 100 mL	14	0	0	0	0	0	0	0