

**ENTEBBE AREA****Report date:** 20<sup>th</sup> October -2015**Table:** Water quality for Selected points in Entebbe during the week starting 12<sup>th</sup> October 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Airport	Airport control Tower	Merryland	Imperial Resort	
CODE		N031	N032	N033	N034	N035	N036	
pH	....	7.3	6.9	7.5	7.6	7.3	6.5	5.5 – 8.5
Turbidity	NTU	2.06	0.10	0.30	0.40	0.80	0.30	≤5.00
Colour	PtCo.	27	0	2	0	3	1	≤15
Iron	Mg/l	0.060	0.000	NR	NR	NR	NR	≤0.300
Residue Aluminium	Mg/l	N/R	0.00	NR	NR	NR	NR	≤0.20
Free chlorine	mg/L	N/R	0.74	0.40	0.20	0.30	0.20	0.20 – 0.50
Faecal-Coliform	CFU/100 mL	39	0	0	0	0	0	0

NR: Not required