

FORT PORTAL AREA**Report date:** 13th January-2016**Table:** Water quality for Selected zones in Fort portal during the week of 7th January-2016.

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Njara Reservoir	Water in Supply			
					Town Center	Kachwamba	Kiculeta	
CODE		N057	N058	N059	N060	N061	N062	
pH	7.7	7.4	7.4	7.4	7.4	7.5	5.5 – 8.5
Turbidity	NTU	16.00	0.00	0.00	0.00	0.00	1.00	≤5.00
Colour	PtCo.	182	10	11	11	10	12	≤15
Iron	Mg/L	0.550	0.000	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/L	N/A	0.10	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	N/A	1.00	1.30	0.25	0.20	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	214	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required