

**FORT PORTAL AREA****Report date:** 5<sup>th</sup> July -2015**Table:** Water quality for selected points in Fort portal during the week of 1<sup>st</sup> July 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw Water R.Mpa nga	Final Water	Water in Supply					
				Njara Reservoirs	Boma	Bukwali	Fort Portal Town Center	Muchwa	
pH	...	7.2	7.3	7.4	7.4	7.3	7.5	7.9	6.5 – 8.5
Turbidity	NTU	18	0.00	0.00	1.00	0.00	0.00	1.00	≤5.00
Colour	PTU	65	8	7	8	9	9	10	≤15
Free chlorine	mg/l	NA	0.70	0.35	0.25	0.20	0.20	0.20	0.20 – 0.50
Faecal - Coliforms	CFU/100 ml	78	0	0	0	0	0	0	0