

FORT PORTAL AREA**Report date:** 2nd November -2015**Table:** Water quality for Selected points in Fort Portal during the week of 26th October 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final Water		Water in Supply			
				Njara Reservoir	Halubaho	Kaswa	Rwengoma	
Codes		N028	N029	N030	N031	N032	N033	
Ph	7.5	7.3	7.3	7.3	7.4	7.4	5.5 – 8.5
Turbidity	NTU	16.00	1.00	0.00	1.00	1.00	0.00	≤5.00
Colour	PtCo.	148	10	11	10	10	8	≤15
Iron	Mg/l	0.60	0.05	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/l	N/A	0.15	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	mg/L	N/A	1.00	0.30	0.20	0.20	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	422	0	0	0	0	0	0

NR: Not Required, NA: Not Applicable