

FORT PORTAL AREA**Report date:** 8th December -2015**Table:** Water quality for Selected zones in during the wee **Fort portal** of starting 3rd December 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Njara Reservoir	Town Center	Kabegira	Mpanga	
Codes		N046	N047	N048	N049	N050	N051	
pH	...	7.5	7.3	7.3	7.3	7.3	7.3	5.5 – 8.5
Turbidity	NTU	13.00	0.00	0.00	0.00	1.00	1.00	≤5.00
Colour	PtCo.	128	10	11	10	12	11	≤15
Iron	Mg/l	0.63	0.05	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/l	N/A	0.10	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	mg/L	N/A	1.20	0.35	0.25	0.20	0.25	0.20 – 0.50
Faecal Coliform	CFU/ 100 mL	264	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required