

**FORT PORTAL AREA****Report date:** 16<sup>th</sup> November-2015**Table:** Water quality for Selected points in Fort Portal during the week of **12th** November 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final Water		Water in Supply			
				Njara Reservoir	Town Center	Harukot o	Karambi	
Codes		N040	N041	N042	N043	N044	N045	
Ph	....	7.6	7.3	7.4	7.4	7.3	7.4	5.5 – 8.5
Turbidity	NTU	10.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	98	0	4	2	5	6	≤15
Iron	Mg/l	0.60	0.05	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/l	N/A	0.15	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	mg/L	N/A	1.00	0.30	0.20	0.25	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	286	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required