

**FORT PORTAL AREA****Report date:** 20<sup>th</sup> October -2015**Table:** Water quality for Selected points in Fort Portal during the week starting 12<sup>th</sup> October 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final Water	Water in Supply					
				Njara Res	Fort Portal Town	Kisenyi	Kasusu	Vilika	
Codes		N015	N016	N017	N018	N019	N020	N021	
Ph	....	7.6	7.2	7.3	7.3	7.3	7.3	7.3	5.5 – 8.5
Turbidity	NTU	14.00	0	0	0	0	0	0	≤5.00
Colour	PtCo.	155	5	6	7	6	9	8	≤15
Iron	Mg/l	0.500	0.050	N/R	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	N/A	0.09	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	mg/L	N/A	1.00	0.35	0.25	0.25	0.20	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	368	0	0	0	0	0	0	0

NR: Not required