

FORT PORTAL AREA**Report date:** 29th June -2015**Table:** Water quality for different zones in Fort portal during the week of 22nd June 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw Water R.Mpanga	Final Water	Water in Supply				
				Njara	Bukwali	Fort Portal taxi Park	Boma	
pH	...	7.97	7.74	7.6	7.6	7.7	7.8	6.5 – 8.5
Turbidity	NTU	17	0	1	1	0	1	≤5.00
Colour	PTU	86	9	9	12	10	13	≤15
Free chlorine	mg/l	N/A	1.7	0.4	0.2	0.3	0.2	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	214	0	0	0	0	0	0