

**FORT PORTAL AREA****Report date:** 30<sup>th</sup> December- 2015**Table:** Water quality for Selected zones in Fort Portal during the week of 24<sup>th</sup> December 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final Water	Water in Supply				
				Njara Reservoir	Town Center	Bukwali	Mpanga	
CODE		N057	N058	N059	N060	N061	N062	
pH	...	7.7	7.4	7.4	7.4	7.5	7.4	5.5 – 8.5
Turbidity	NTU	22.00	0.00	0.00	1.00	1.00	1.00	≤5.00
Colour	PtCo.	166	10	11	12	12	11	≤15
Iron	mg/l	0.63	0.05	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	mg/l	N/A	0.10	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	mg/L	N/A	1.20	0.30	0.25	0.20	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	212	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required