

FORT PORTAL AREA

Report date: 13th July -2015

Table: Water quality for selected zones in Fort portal during the week of 6th July 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw Water R.Mpanga	Final Water	Water in Supply				
				Fort Portal Town Center	Bukwali	Boma	Muchwa	
pH	...	7.1	7.0	7.2	6.9	7.1	7.3	6.5 – 8.5
Turbidity	NTU	11	0	0	0	0	0	≤5.00
Colour	PTU	49	4	3	5	5	4	≤15
Free chlorine	mg/l	NA	0.55	0.23	0.31	0.25	0.20	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	21	0	0	0	0	0	0