



**NATIONAL WATER & SEWERAGE CORPORATION  
WATER QUALITY MANAGEMENT DEPARTMENT**

**GULU AREA**

**Report date:** 9<sup>th</sup> March 2016

**Table:** Water quality for Selected zones in Gulu during the week of 3<sup>rd</sup> March, 2016.

Parameter	Unit	Monitoring Points							National Standards for potable water quality; Water in supply
		Waterworks			Water in Supply				
		Raw water	Final water	Church Hill Courts Hotel	Binen Pork Joint	Binen Hotel	Kakanyero Hotel	Palema Hotel	
Sample No.		N1076	N1077	N1086	N1087	N1088	N1089	N1090	
pH	...	6.6	6.8	7.2	7.5	7.7	7.6	7.7	5.5 – 8.5
Colour	PtCo.	108	5	11	10	12	13	9	≤15
Turbidity	NTU	15.40	0.90	1.68	10.40	3.57	5.76	3.25	≤5.00
Iron (Total)	mg/L	0.25	0.001	0.313	0.170	0.050	0.060	0.060	0.300
Res. Aluminium	mg/L	N/A	0.18	N/R	N/R	N/R	N/R	N/R	0.20
Free chlorine	mg/L	N/A	1.22	0.23	0.46	0.32	0.22	0.21	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	480	0	0	0	0	0	0	0

N/A: Not applicable, N/R: Not Required