

## GULU AREA

**Report date:** 14<sup>th</sup> December-2015

**Table:** Water quality for Selected zones in Gulu during the week of 10<sup>th</sup> December-2015

Parameters	Units	Monitoring Points							National Standards For potable water quality (Water in Supply)
		Raw water	Final water	Water in Supply					
				Boma Reser voir	Kanyo goga	World Vision	Gulu Hospit al	African Quarter s	
CODE		N682	N683	N684	N685	N686	N687	N688	
pH		7.0	6.6	6.8	6.8	7.0	6.9	6.9	5.5-8.5
Colour	PtCo	600	8	9	10	9	8	10	≤15
Turbidity	NTU	48.8	0.98	1.11	1.02	1.10	0.99	1.08	≤5.00
Iron: Total	Mg/L	1.54	0.22	N/R	N/R	N/R	N/R	N/R	<0.30
Residual Aluminium	Mg/L	N/A	0.2	N/R	N/R	N/R	N/R	N/R	≤0.2
Free chlorine	Mg/L	N/A	1.5	0.90	0.28	0.30	0.38	0.22	0.20-0.50
Faecal coliform	CFU/100 mL	140	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required