

GULU AREA**Report Date:** 2nd November 2015**Table:** Water Quality for Selected Zones in Gulu during the week starting 26th October 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Custom Reservoir	Pece Reservo ir	Pece Tegwana	Dr. Latigo Koroo	Layibi Coner	
CODE		N421	N422	N423	N424	N429	N426	N427	
pH	...	7.14	7.23	7.14	7.23	7.42	7.63	7.54	5.5 – 8.5
Turbidity	NTU	37.7	1.05	0.01	1.75	1.22	0.85	3.69	≤5.00
Colour	PtCo.	287	12	10	12	15	10	12	≤15
Iron	mg/L	0.288	0.09	ND	ND	ND	ND	ND	≤0.30
Residue Aluminium	Mg/L	N/R	0.1	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	N/A	1.99	1.3	0.8	0.2	0.14	0.15	0.20 – 0.50
Feacal coliforms	CFU/100 mL	133	0	0	0	0	0	0	0

NA: Not applicable, NR: Not Reported