

## GULU AREA

**Report date:** 8<sup>th</sup> December-2015

**Table:** Water quality for Selected zones in Gulu during the week starting 3<sup>rd</sup> December-2015

Parameters	Units	Monitoring Points							National Standards For potable water quality (Water in Supply)
		Raw water	Final water	Water in Supply					
				Pece Reser voir	Golden Peace	Koch Goma Rd	Gulu Univer sity	Laroo Div.	
CODE		N537	N538	N539	N540	N541	N542	N543	
pH		7.0	6.8	7.3	6.9	7.1	7.1	6.9	5.5-8.5
Colour	PtCo	1110	10	12	12	11	14	15	≤15
Turbidity	NTU	56.62	2.18	2.8	2.77	2.23	3.55	2.88	≤5.00
Iron: Total	mg/L	1.64	0.32	N/R	N/R	N/R	N/R	N/R	<0.30
Free chlorine	mg/L	N/A	1.5	0.9	0.28	0.3	0.38	0.22	0.20-0.50
Faecal coliform	CFU/100 mL	320	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required