

GULU AREA

Report Date: 20th October 2015

Table: Water Quality for Selected Zones in Gulu during the week starting 12th October 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				Gulu Hospital	Laroo TC	Oyat Lacor	Odongo Lacor	Kakuuto Pece	
CODE		N362	N363	N371	N371	N368	N369	N370	
pH	...	7.2	7.3	7.2	7.3	7.3	7.4	7.2	5.5 – 8.5
Turbidity	NTU	20.50	1.85	2.18	2.12	1.88	0.92	0.89	≤5.00
Colour	PtCo.	145	13	16	20	13	8	10	≤15
Aluminium resd.	mg/L	NA	0.10	NR	NR	NR	NR	NR	0.20
Free chlorine	mg/L	NA	0.78	0.38	0.4	0.29	0.24	0.20	0.20 – 0.50
Feacal coliforms	CFU/ 100 mL	NT	4000	0	0	0	0	0	0

NR: Not required