

GULU AREA**Report date:** 22nd June 2015.**Table:** Average water quality for different zones in Gulu during the week of 15th June 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Reservoirs	Water in Supply				
				Kirombe	Sir Samuel Baker	Bunyoro Rd	Gasco energy	Tegwane	
pH	6.46	5.93	6.07	5.89	5.97	6.09	6.09	5.5 – 8.5
Turbidity	NTU	32.7	1.44	1.24	0.95	1.89	0.77	1.20	≤5
Colour	PtCo.	305	8	11	10	15	1	11	≤15
Free chlorine	mg/L	.N/A	1.17	0.22	0.2	0.15	0.3	0.22	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	22	0	0	0	0	0	0	0