

## GULU AREA

**Report date:** 24<sup>th</sup> December-2015

**Table:** Water quality for Selected zones in Gulu during the week of 17<sup>th</sup> December-2015

Parameters	Units	Monitoring Points							National Standards For potable water quality (Water in Supply)
		Raw water	Final water	Water in Supply					
				Custo ms Reser voir	Boma Reserv oir	Pece Labour line	Senior Quarte rs	Oil Energy	
CODE		N669	N670	N671	N672	N673	N674	N675	
pH		7.8	7.76	8.4	7.6	7.0	6.9	6.9	5.5-8.5
Colour	PtCo	97	2	10	12	12	14	15	≤15
Turbidity	NTU	14.7	2.82	2.02	2.11	2.29	2.09	2.96	≤5.00
Iron: Total	Mg/L	0.94	0.18	N/R	N/R	N/R	N/R	N/R	<0.30
Residual Aluminium	Mg/L	N/A	0.10	N/R	N/R	N/R	N/R	N/R	≤0.2
Free chlorine	Mg/L	N/A	1.00	0.20	0.25	0.21	0.20	0.25	0.20-0.50
Faecal coliform	CFU/100 mL	80	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required