

**GULU AREA****Report date:** 24<sup>th</sup> July -2015**Table:** Water quality for selected points in Gulu during the week of 20<sup>th</sup> July 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water	Water in Supply				
				Layibi Trading Centre	Pece Lukung	Senior Quarters	Golden Peace	
pH	...	7.1	7.3	7.4	7.6	7.4	7.6	6.5 – 8.5
Turbidity	NTU	33.50	1.30	0.70	0.60	0.80	2.30	≤5.00
Colour	PTU	222	10	06	12	1	05	≤15
Free chlorine	mg/l	N/A	0.76	0.12	0.22	0.22	0.21	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	80	0	0	0	0	0	0