

GULU AREA**Report date:** 29th June -2015**Table:** Water quality for different zones in Gulu during the week of 22nd June 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water r	Reservoirs	Water in Supply			
				Kirombe	Bardege division	Layibi division	Pece division	
pH	6.66	6.17	6.65	5.91	5.77	5.58	5.5 – 8.5
Turbidity	NTU	161.6	205.7	203	197	201	210	≤5
Colour	PtCo.	1080	13	9	11	14	6	≤15
Free chlorine	mg/L	N/A	0.94	0.26	0.22	0.30	0.26	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	17	0	0	0	0	0	0