

**GULU AREA****Report date:** 26<sup>th</sup> September -2015**Table:** Water quality for Selected points in Gulu during the week of 25<sup>th</sup> September, 2015

Parameter	Unit	Monitoring points							National Standards for potable water
		Raw water	Final water	Water in Supply					
				Bomah	UN Office	Gohans Qts	WFP	Tegwan a	
CODES		N300	N301	N302	N305	N306	N307	N308	
pH	...	6.89	7.12	7.3	6.66	6.78	7.12	7.2	5.5 – 8.5
Turbidity	NTU	103	1.44	2.01	2.56	3.03	4.51	2.36	≤5.00
Colour	PtCo.	1940	9	10	12	14	15	12	≤15
Iron	mg/L	0.23	0.12	N/R	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	mg/L	N/R	0.1	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/A	1.2	1.01	0.32	0.25	0.3	0.34	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	ND	0	0	0	0	0	0	0

N/R-Not Required