

## GULU AREA

**Report date:** 13<sup>th</sup> June -2015

**Table:** Water quality for selected zones s in Gulu during the week of 6<sup>th</sup> July 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Kabedopon g	Tegwana pece	Sir baker road	Layibi bunyoro road	
pH	....	7.1	7.3	7	6.8	7.1	6.7	5.5 – 8.5
Turbidity	NTU	143.4	2.64	2.72	2.81	3.11	3.51	≤5
Colour	PtCo.	824	12	14	13	15	15	≤15
Free chlorine	mg/L	N/A	0.8	0.5	0.3	0.4	0.2	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	75	0	0	0	0	0	0