

GULU AREA**Report Date:** 7th October 2015**Table:** Water Quality for Selected Zones in Gulu during the week of 2nd October 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Kanyogoga	Golden peace	Salvatori Rd	Obia west Iacor	Peace Tegwana	
CODE		N320	N321	N325	N326	N327	N328	N329	
pH	...	7.5	7.6	7.4	7.3	7.4	7.5	7.8	5.5 – 8.5
Turbidity	NTU	29.00	0.61	1.61	0.74	2.01	0.70	2.23	≤5.00
Colour	PtCo.	232	10	15	13	14	11	12	≤15
Aluminium resd.	mg/L	NA	0.10	NR	NR	NR	NR	NR	0.20
Free chlorine	mg/L	NA	1.20	0.22	0.20	0.20	0.20	0.20	0.20 – 0.50
Feacal coliforms	CFU/ 100 mL	NT	120	0	0	0	0	0	0