



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

HOIMA AREA

Report date: 12th Oct 2016

Table: Water quality for Selected zones in **HOIMA** during the week ending 6th Oct 2016

Parameter				Monitoring points						National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply					
				Hoima Reservoir	Kiryatete PSP	Nwsc office		Masindi rd Kisiramumu	Kibingo	
Codes										
pH	7.6	7.8	7.9	8.0	8.0		8.0	8.1	5.5 – 8.5
Turbidity	NTU	10.34	0.76	1.00	1.22	0.97		0.35	0.57	≤5.00
Colour	PtCo.	70	5	1	1	0		0	0	≤15
Free chlorine	mg/L	N/R	0.5	0.44	0.36	0.39		0.33	0.36	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	-	0	0	0	0		0	0	0