

HOIMA AREA**Report date:** 6th July 2015**Table:** Water quality for selected points in Hoima during the week of 1st July 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply				
				Bujumbur a-Hoido	Kyarwabu yamba	Kibati	Kibingo	
pH	...	7.8	7.9	8.0	8.1	8.1	8.1	5.5 – 8.5
Turbidity	NTU	24.4	1.83	0.56	1.55	0.78	0.90	≤5.00
Colour	PtCo.	241	5	5	7	4	4	≤15
Free chlorine	mg/L	6	0.62	0.29	0.42	0.36	0.24	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	6	0	0	0	0	0	0