

HOIMA AREA**Report date:** 13th July 2015**Table:** Water quality for selected points in Hoima during the week of 6th July 2015

Parameter	Monitoring points						National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply			
				Kiganda psp	NWSC office	kyarwabuyamba	
pH	...	7.76	7.91	8.02	8.1	8.05	5.5 – 8.5
Turbidity	NTU	13.6	0.97	1.61	0.69	2.02	≤5
Colour	PtCo.	435	6	459	410	464	≤15
Free chlorine	mg/L	38	0.47	4	3	0	0.20 – 0.50
Faecal -Coliform	CFU/ 100 mL	0	0.47	0.37	0.22	0.4	0