



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

JINJA AREA

Report date: 10th Oct 2016

Table: Water quality for selected points **Jinja** Area during the week ending 6th Oct 2016

Table: Water quality for selected points in Juba Area during the week ending 8 Oct 2018									
Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw Water	Treated Water	Water in Supply					
				Oboja road	Busoga avenue	Kaitaba wala	Budond o	Kimaka	
Codes		N1189	N1190	N1191	N1192	N1193	N1194	N1195	
pH		7.9	7.7	7.3	7.3	7.5	7.5	7.4	6.5 – 8.5
Turbidity	NTU	39	1.90	1.50	2.00	1.80	1.60	1.50	≤5.00
Colour	PTU	149	4	4	5	3	2	3	≤15
Iron	mg/l	0.06	0.02	0.02	0.01	0.01	0.00	0.01	0.30
Residual Al	mg/l	N/A	0.00	0.00	0.00	0.00	0.00	0.00	0.20
Free chlorine	mg/l	N/A	1.6	0.30	0.35	0.20	0.20	0.25	0.2-0.5
Faecal - Coliforms	CFU/ 100 ml	6	0	0	0	0	0	0	0

NA: Not applicable