



**NATIONAL WATER & SEWERAGE CORPORATION  
WATER QUALITY MANAGEMENT DEPARTMENT**

**JINJA AREA**

**Report date:** 10<sup>th</sup> June 2016

**Table:** Water quality for selected zones in Jinja Area during the week of 2<sup>nd</sup> June 2016

Table 1: Water quality for selected zones in Jinja Area during the week of 2 – 8 June 2018									
Parameter	Unit	Raw Water	Treated Water	Monitoring points					National Standard For potable water quality (Water in Supply)
				Water in Supply					
				Walukuba Reservoir	Nakibizi	Mpumudd e	Katende Rd	Babu	
Codes		N601	N602	N603	N604	N605	N606	N607	
pH		7.5	7.3	7.4	7.4	7.2	7.3	7.3	5.5 – 8.5
Turbidity	NTU	2.5	0.68	0.73	0.61	0.49	0.56	0.65	≤5.00
Colour	PTU	35	8	5	5	3	2	4	≤15
Iron	mg/l	0.08	0.01	0.02	0.00	0.01	0.00	0.00	≤0.300
Residual Al	mg/l	N/A	0.06	0.08	0.09	0.1	0.08	0.08	≤0.20
Free chlorine	mg/l	N/A	1.6	0.40	0.35	0.20	0.31	0.20	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	4	0	0	0	0	0	0	0

NA: Not applicable