



**NATIONAL WATER & SEWERAGE CORPORATION  
WATER QUALITY MANAGEMENT DEPARTMENT**

**JINJA AREA**

**Report date:** 2<sup>nd</sup> March 2016

**Table:** Water quality for selected points Jinja Area during the week of 25<sup>th</sup> February 2016

Table: Water quality for selected points Jinja Area during the week of 23 - February 2018									
Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw Water	Treated Water	Water in Supply					
				Mbiko	Lubas Market	Kayitab awala	Danida	Masese	
Codes		N152	N153	N154	N155	N156	N157	N158	
pH		7.6	7.4	7.6	7.6	7.5	7.4	7.5	6.5 – 8.5
Turbidity	NTU	2.88	0.58	0.61	0.53	0.68	0.64	0.73	≤5.00
Colour	PTU	47	05	06	05	06	06	08	≤15
Iron	mg/l	0.13	0.05	0.02	0.00	0.01	0.00	0.01	0.30
Residual Al	mg/l	N/A	0.00	0.00	0.00	0.00	0.00	0.00	0.20
Free chlorine	mg/l	N/A	1.0	0.20	0.17	0.15	0.12	0.19	0.2-0.5
Faecal - Coliforms	CFU/ 100 ml	15	0	0	0	0	0	0	0

NA: Not applicable