

## JINJA AREA

Report date: 8<sup>th</sup> June 2015

**Table:** Average water quality for Jinja during the period of 1<sup>st</sup> June - 7<sup>th</sup> June 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw Water L. Victoria	Treated Water Water Works	Water in Supply					
				Jinja Central	Walukuba -Masese	Mpummude	Bugembe	Njeru	
pH	...	7.7	7.5	7.5	7.5	7.4	7.5	7.6	6.5 – 8.5
Turbidity	NTU	3.8	0.7	0.2	0.1	0.2	0.3	0.2	≤5.00
Colour	PTU	43.5	7	3	9	0	2	5	≤15
Free chlorine	mg/l	N/A	0.5	0.3	0.2	0.3	0.3	0.2	0.20 – 0.50
Faecal -Coliforms	CFU/ 100 ml	20	0	0	0	0	0	0	0

