

JINJA AREA

Report date: 14th December -2015

Table: Water quality for Selected points in **Jinja** during the week of 10th December 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				Mafubira	Babu	Nile Cresce nt	Nakibiz i	Wanyam a	
Codes		N082	N083	N084	N085	N086	N087	N088	
pH	6.9	7.2	7.1	7.0	7.0	7.1	7.2	5.5 – 8.5
Turbidity	NTU	2.1	0.58	0.75	0.41	0.80	0.74	0.56	≤5.00
Colour	PtCo.	46	8	11	3	8	10	9	≤15
Iron	Mg/L	0.20	0.03	0.02	0.04	0.05	0.02	0.06	≤0.30
Residue Aluminium	Mg/L	N/A	0.00	0.02	0.00	0.00	0.00	0.00	≤0.20
Free chlorine	Mg/L	N/A	0.96	0.20	0.20	0.20	0.20	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	2	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required