

JINJA AREA**Report date:** 30th November -2015**Table:** Water quality for selected points Jinja Area during the week of 26th November 2015

Parameter	Monitoring points								National Standard For potable water quality
	Unit	Raw Water	Treat ed Water	Water in Supply					
				Masese	Bugem be	Kisinja	Njeru	waluku ba	
Codes		N068	N069	N070	N071	N072	N073	N074	
pH	NA	7.4	7.4	7.3	7.4	7.3	7.4	7.5	6.5 – 8.5
Turbidity	NTU	3.19	0.97	1.34	0.94	1.11	0.98	1.37	≤5.00
Colour	PTU	38.5	10	13	8	9	7	10	≤15
Iron	mg/l	0.16	0.06	0.04	0.02	0.04	0.05	0.07	0.30
Residual Al	mg/l	N/A	0.00	0.00	0.00	0.02	0.01	0.00	0.20
Free chlorine	mg/l	N/A	1.5	0.18	0.22	0.36	0.32	0.20	0.2-0.5
Faecal - Coliforms	CFU/ 100 ml	12	0	0	0	0	0	0	0

NA: Not applicable