

JINJA AREA**Report date:** 16th Nov ember**Table:** Water quality for selected points Jinja Area during the week of 12th November 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw Water	Treat ed Water	Water in Supply					
				Mpumudd e PSP	Waluku ba West	Masese PSP	Lubas Mkt	Mbiko	
Codes		N055	N056	N057	N058	N059	N060	N061	
pH	...	7.6	7.5	7.40	7.5	7.5	7.6	7.4	6.5 – 8.5
Turbidity	NTU	1.7	0.4	0.5	0.7	0.8	0.60	0.50	≤5.00
Colour	PTU	44	5	5	7	7	8	5	≤15
Iron	mg/l	0.05	0.01	0.01	0.02	0.01	0.00	0.00	0.30
Residual Al	mg/l	N/A	0.00	0.01	0.00	0.00	0.01	0.00	0.20
Free chlorine	mg/l	N/A	1.1	0.23	0.26	0.23	0.25	0.20	0.2-0.5
Faecal - Coliforms	CFU/ 100 ml	12	0	0	0	0	0	0	0

NA: Not applicable