

**JINJA AREA****Report date:** 9<sup>th</sup> September -2015**Table:** Water quality for Selected points in Jinja during the week of 3<sup>rd</sup> September 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply				
				Jinja Central	Walukub a - Masese	Mpummu de	Bugembe	
Codes		N001	N002	N003	N004	N005	N006	
pH	....	7.5	7.6	7.5	7.5	7.6	7.6	5.5 – 8.5
Turbidity	NTU	2.60	0.97	0.80	1.10	0.90	1.00	≤5.00
Colour	PtCo.	35	6	3	6	6	5	≤15
Iron	Mg/l	0.090	0.020	0.020	0.000	0.010	0.020	≤0.300
Residue Aluminium	Mg/l	-	0.00	0.00	0.00	0.00	0.00	≤0.20
Free chlorine	mg/L	N/A	0.70	0.20	0.2	0.31	0.40	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	10	0	0	0	0	0	0