

JINJA AREA**Report date:** 22nd June 2015**Table:** Average water quality for selected Zones in Jinja during the week of 15th June 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw Water L. Victoria	Treated Water Water Works	Water in Supply					
				Jinja Central	Walukuba -Masese	Mpummude	Bugembe	Njeru	
pH	...	7.56	7.51	7.55	7.56	7.49	7.48	7.44	6.5 – 8.5
Turbidity	NTU	3.5	0.25	0.28	0.25	0.32	0.36	0.39	≤5.00
Colour	PTU	40	3.0	2.2	5.0	4.0	2.5	4.0	≤15
Free chlorine	mg/l	N/A	1.28	0.29	0.24	0.23	0.30	0.21	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	32	0	0	0	0	0	0	0