

**JINJA AREA****Report date:** 27<sup>th</sup> July -2015**Table:** Water quality for selected points in Jinja during the week of 20<sup>th</sup> July 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw Water L. Victori a	Treate d Water Water Works	Water in Supply					
				Jinja Centra l	Waluk uba - Mases e	Mpum mude	Buge mbe	Njeru	
pH	---	7.5	7.4	7.4	7.4	7.4	7.4	7.4	6.5 – 8.5
Turbidity	NTU	3.70	0.25	0.26	0.24	0.22	0.30	0.35	≤5.00
Colour	PTU	41	2	1	4	3	4	4	≤15
Free chlorine	mg/l	N/A	1.00	0.22	0.19	0.25	0.26	0.25	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	32	0	0	0	0	0	0	0