

**JINJA AREA****Report date:** 29<sup>th</sup> June -2015**Table:** Water quality for different zones in Jinja during the week of 22<sup>nd</sup> June 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw Water L. Victoria	Treated Water Water Works	Water in Supply					
				Jinja Central	Walukuba -Masese	Mpummude	Bugembe	Njeru	
pH	...	7.48	7.43	7.45	7.47	7.46	7.42	7.41	6.5 – 8.5
Turbidity	NTU	3.9	0.36	0.34	0.52	0.43	0.66	0.53	≤5.00
Colour	PTU	37	4	6	4	7	5	6	≤15
Free chlorine	mg/l	N/A	1.10	0.23	0.28	0.27	0.21	0.18	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	35	0	0	0	0	0	0	0