

JINJA AREA**Report date:** 25th Nov ember**Table:** Water quality for selected points Jinja Area during the week of 19th November 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw Water	Treated Water	Water in Supply				
				Jinja central	Walukub a masese	Bugem be	Njeru	
Codes		N062	N063	N064	N065	N066	N067	
pH	...	7.8	7.6	7.5	7.5	7.6	7.5	6.5 – 8.5
Turbidity	NTU	3.68	1.14	0.81	0.70	0.65	1.19	≤5.00
Colour	PTU	53	12	10	9	7	12	≤15
Iron	mg/l	0.17	0.03	0.00	0.01	0.03	0.02	0.30
Residual Al	mg/l	N/A	0.00	0.00	0.00	0.01	0.00	0.20
Free chlorine	mg/l	N/A	0.93	0.22	0.25	0.20	0.22	0.2-0.5
Faecal - Coliforms	CFU/ 100 ml	14	0	0	0	0	0	0

N/A: Not applicable