

KABALE AREA**Report date:** 13th January-2016**Table:** Water quality for Selected zones in Kabale during the week of 7th January-2016.

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Makanga Reservoir	Water in Supply			
					Kabale Town center	Nyabikoni Zone	Kekubo	
CODE		N010	N011	N012	N013	N014	N015	
pH	6.7	7.0	6.9	6.9	6.9	6.9	5.5 – 8.5
Turbidity	NTU	2.50	0.94	0.75	0.64	0.35	0.45	≤5.00
Colour	PtCo.	24	8	9	7	6	7	≤15
Iron	Mg/L	1.500	0.050	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/L	N/A	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	N/A	0.90	0.40	0.22	0.25	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	5	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required