



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

KABALE AREA

Report date: 12th Oct 2016

Table: Water quality for Selected zones in **KABALE AREA** during the week ending 6th Oct 2016

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				Makanga Lower Reservoir	Rutooma	Nyabikoni	Kabale NTC	Kekubo	
Codes		-	-	-	-	-	-	-	
pH	7.5	7.6	7.6	7.5	7.5	7.6	7.2	5.5 – 8.5
Turbidity	NTU	2.81	0.76	0.30	0.28	0.40	0.39	0.29	≤5.00
Colour	PtCo.	31	5	5	4	6	5	4	≤15
Free chlorine	mg/L	N/R	1.54	0.35	0.24	0.29	0.20	0.25	0.20 – 0.50
Faecal - Coliform	CFU/100 mL	--	-	0	0	0	0	0	0