

**KABALE AREA**Report date: 5<sup>th</sup> July -2015

Table: Water quality for selected zones in Kabale during the week of 1st July 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				Lugara ma. Reserv oirs	Kabale Town Center	Mwend o Trading Center	Kigongi Zone	Nyabiko ni	
pH	....	6.6	6.5	6.4	6.6	6.4	6.5	6.3	5.5 – 8.5
Turbidity	NTU	3.50	1.00	1.00	1.00	1.00	0.00	1.00	≤5.00
Colour	PtCo.	31	9	8	9	9	10	10	≤15
Free chlorine	mg/L	NA	0.83	0.25	0.25	0.20	0.20	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	5	0	0	0	0	0	0	0