

**KABALE AREA****Report date:** 16<sup>th</sup> November-2015**Table:** Water quality for Selected zones in Kabale during the week of 12<sup>th</sup> November 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply				
				Makanga Reservoir	Mwanjari	Kabale Central Town	Mwendo	
Codes		N029	N030	N031	N032	N033	N034	
pH	....	7.0	7.0	7.1	6.9	6.9	6.8	5.5 – 8.5
Turbidity	NTU	1.90	0.80	0.49	0.53	0.50	0.69	≤5.00
Colour	PtCo.	27	10	12	9	8	6	≤15
Iron	Mg/l	N/R	N/R	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/l	N/A	N/A	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/A	0.90	0.40	0.20	0.15	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	N/R	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required