

KABALE AREA**Report date:** 29th June -2015**Table:** Water quality for different zones in Kabale during the week of 22nd June 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water L. Bunyonyi	Final water	Water in Supply					
				Makanga	Kabale Town centre	Mwendo	Kigongo	Nyabiko ni	
pH	6.7	6.4	6.4	6.2	6.3	6.3	6.4	5.5 – 8.5
Turbidity	NTU	5	2	2	1	1	1	1	≤5
Colour	PtCo.	29	12	11	10	11	10	10	≤15
Free chlorine	mg/L	N/A	0.6	0.4	0.3	0.3	0.2	0.2	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	33	0	0	0	0	0	0	0