

KABALE AREAReport date: 27th July -2015Table: Water quality for selected points in Kabale during the week of 20th July 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water r L. Bunyonyi	Final water	Water in Supply					
				Makanga. Reservoir	Kabale Town Center	Mwendo Trading Center	Kigongi Zone	Nyabikoni	
pH	6.7	6.5	6.5	6.6	6.7	6.8	6.8	5.5 – 8.5
Turbidity	NTU	6.00	2.00	1.00	1.00	2.00	1.00	0.00	≤5.00
Colour	PtCo.	27	11	9	9	10	10	8	≤15
Free chlorine	mg/L	N/A	0.72	0.42	0.26	0.25	0.35	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	31	0	0	0	0	0	0	0