

KABALE AREA**Report date:** 13th July -2015**Table:** Water quality for selected zones in Kabale during the week of 6th July 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water L. Bunyonyi	Final water	Water in Supply				
				Kabale Town Center	Kigongi Zone	Mwendo Trading Center	Nyabikoni zone	
pH	6.7	6.3	6.3	6.1	6.2	6.2	5.5 – 8.5
Turbidity	NTU	4	0	0	0	0	0	≤5
Colour	PtCo.	29	8	8	8	7	9	≤15
Free chlorine	mg/L	NA	0.69	0.2	0.3	0.2	0.2	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	24	0	0	0	0	0	0